

SAN DIEGO GAS & ELECTRIC
GAS QUALITY
QUARTERLY SULFUR REPORT

Pipeline System Receipt Point

1/1/2009 - 3/31/2009

4/1/2009 - 6/31/2009

7/1/2009 - 9/30/2009

Hydrogen Sulfide Maximum (Grains/100scf)		Total Organic Sulfur Maximum (Grains S/100scf)	
Rainbow	Oceanside	Rainbow	Oceanside
< 0.25	< 0.25	< 0.75	< 0.75
< 0.25	< 0.25	< 0.75	< 0.75
< 0.25	< 0.25	< 0.75	< 0.75

* Sulfur content meets California Public Utility Commission (CPUC) natural gas requirements as defined in General Order 58A.

This is provided for information purposes only. SDG&E publication nor verbal representations thereof constitutes any statement, recommendation, endorsement, approval or guaranty (either express or implied) of any product or service. Moreover, SDG&E shall not be responsible for errors or omissions in this publication, for claims or damages relating to the use thereof, even if it has been advised of the possibility of such damages.