Presentation on SDG&E's 2018 Annual Electric Reliability Results October 2, 2019








Classifications of our Assets





Reliability statistics are broken down by Transmission, Substation, and Distribution

Reliability Goals and Metrics



- SDG&E's goal is to:
 - Provide our customers with safe and reliable power.
 - Improve reliability by reducing the number of outages, and their duration, experienced by our customers.
 - Review all outages and causes, validate trends, and mitigate for issues identified.
- The four metrics to measure performance:
 - System Average Interruption Duration Index (SAIDI)
 - SAIDI measures the average outage time experienced by customers.
 - System Average Interruption Frequency Index (SAIFI)
 - SAIFI is the average number of times a customer experienced a sustained outage in a given year.
 - Customer Average Interruption Duration Index (CAIDI)
 - CAIDI is the average time required to restore service to a customer.
 - Momentary Average Interruption Frequency Index (MAIFI)
 - MAIFI is the average number of momentary outages per customer per year.
- Major Event Day (MED): A day in which the daily system SAIDI exceeds a threshold value.

Examples of Our Reliability Programs



- SDG&E's focus is to build a strategy around overall system-wide performance in both outage duration and frequency.
 - Fire Risk Mitigation (FiRM) Fire prevention, safety, and reliability with a primary focus towards lowering public safety risk due to wildfires and to optimize reliability improvements. Wood poles are replaced by steel, and larger conductor replaces smaller conductor for greater strength, better performance.
 - Vegetation Management Systematic, schedule-based approach following a work plan to complete all activities annually; includes pre-inspection, tree pruning, brush clearing. Recognized by National Arbor Day 16 years in a row. and recognized by the CPUC as a model program.
 - Pole Risk Mitigation and Engineering (PRiME) Complete formal strength analysis of all poles in the SDG&E system, confirming poles meet or exceed current standards.

Examples of Our Reliability Programs cont.



- <u>"Tee" Modernization</u> Upgrading major connection points on the underground distribution system to enhance our ability to restore customers when unplanned outages occur.
- Supervisory Control and Data Acquisition (SCADA) Direct operator control of over 2000 switches across the distribution network for quick restoration. New switches are continually added to this system each year.
- <u>Business Services Project Coordination</u> Customer outreach and outage notifications including restoration estimates.

Examples of Our Reliability Programs cont.



 Meteorology - Forecasting weather and conditions for proactive preparations for adverse weather. A new department was established in 2018: "Fire Science and Climate Adaptation", to help focus the combined efforts.

 Proactive Cable Replacement - Planned replacement of underground distribution cables as a function of vintage and recent reliability performance.

 Other Aging Infrastructure - In addition to cables, substations are upgraded where major equipment has reached end of service life, and lower voltage distribution circuits commonly installed many decades ago are upgraded to higher voltage operation for increased capacity.

Examples of Our Reliability Programs cont.



 <u>Inoperative Switches</u> – Replacing or removing switches that are at end of service life, to better facilitate quicker restoration by crews. Some strategically-placed switches are replaced with automated switches for improved outage performance.

 Reducing Vehicle Contacts with Equipment – Relocating key devices to reduce the chances of recurring outages due to vehicle contacts.

 Mylar Balloons – Working with the party balloon industry to help develop an alternative material that will be less likely to cause outages when coming into contact with overhead lines.

Reliability Accomplishments



Awards/Recognition

PA Consulting - Leader in Energy and Utilities Consultation



- Best in the West in Reliability for 14 consecutive years
- 2017 Best in the Nation (awarded in 2018)
- Technology and Innovation Award 2016/17



- Edison Electric Institute 2018 Edison Award
- 2016 CPUC Report Best Investor Owned Utility in CA






How SDGE compares with the other large California utilities?


SAIDI Comparison - Past 5 Years





SAIFI Comparison – Past 5 Years





SDG&E's Annual Report



How to better understand the annual report

- Section 1 System Indices for the last 10 years
- Section 2 District Reliability Indices for the past 10 years including and excluding MED
- Section 3 System and District Indices based on IEEE 1366 for past 10 years including planned outages and including and excluding MED
- Section 4 Service territory map including divisions of districts
- Section 5 Top 1% of Worst Performing Circuits (WPC) excluding MED
- Section 6 Top 10 major unplanned power outage events within a reporting year
- Section 7 Summary List of MED per IEEE 1366
- Section 8 Historical 10 largest unplanned outage events for the past 10 years
- Section 9 Number of customer inquiries on Reliability Data and the number of days per response

Section 1 - System Indices for the Past 10 Years



System Reliability

- Tables of reliability indices for the past 10 years
- Graphs depicting indices for the past 10 years

Table 1-1: System Indices (MED included and excluded)

San Diego Gas & Electric System Reliability Data 2009 - 2018										
	MED Included						MED Excluded			
Year	SAIDI	SAIFI	CAIDI	MAIFI]	SAIDI	SAIFI	CAIDI	MAIFI	
2009	67.06	0.542	123.74	0.380		49.71	0.466	106.60	0.362	
2010	85.37	0.652	130.99	0.510		63.36	0.520	121.80	0.444	
2011	567.59	1.472	385.63	0.239		53.43	0.471	113.44	0.239	
2012	64.36	0.533	120.78	0.301		64.36	0.533	120.78	0.301	
2013	75.03	0.561	133.84	0.211		59.96	0.472	127.03	0.211	
2014	75.81	0.632	119.88	0.262		64.60	0.603	107.16	0.244	
2015	58.11	0.530	109.68	0.347		57.92	0.526	110.09	0.347	
2016	86.01	0.677	126.99	0.443		72.75	0.620	117.43	0.386	
2017	117.49	0.585	200.87	0.344		64.51	0.512	125.92	0.311	
2018	121.02	0.658	183.88	0.319		77.76	0.628	123.84	0.319	

Section 2 - District Indices for the Past 10 Years



- SDG&E's service area is grouped into Six Districts
 - Tables of reliability indices for the past 10 years
 - Graphs depicting indices for the past 10 years

Table 2-2: Eastern – District Reliability Indices (MED included and excluded)

		MED Inc	luded	MED Excluded					
Year	SAIDI	SAIFI	CAIDI	MAIFI	SAIDI	SAIFI	CAIDI	MAIFI	
2009	86.05	0.679	126.66	0.389	60.85	0.596	102.05	0.389	
2010	90.81	0.629	144.41	0.562	54.24	0.443	122.41	0.400	
2011	588.29	1.506	390.55	0.193	65.26	0.507	128.79	0.193	
2012	87.40	0.688	127.07	0.339	87.40	0.688	127.07	0.339	
2013	78.39	0.643	121.93	0.223	77.04	0.634	121.58	0.223	
2014	91.73	0.574	159.75	0.243	77.80	0.528	147.39	0.238	
2015	50.17	0.461	108.79	0.263	50.17	0.461	108.79	0.263	
2016	108.24	0.820	132.06	0.326	84.93	0.705	120.41	0.292	
2017	177.22	0.637	278.38	0.358	83.72	0.529	158.23	0.322	
2018	203.88	0.688	296.39	0.362	108.94	0.654	166.62	0.362	

Section 3 - System and District Indices for the Past 10 Years, Including Planned Outages




The data used to develop the planned outage indices in the report is from an outage management system implemented in late 2012.

- Six years of historical planned outage data is currently available
- 3,000+ system upgrades performed every year to improve your service

System Indices (2013 – 2018) Planned and Unplanned									
	MED Included						MED	Excluded	
Year	SAIDI	SAIFI	CAIDI	MAIFI		SAIDI	SAIFI	CAIDI	MAIFI
2013	106.19	0.668	158.96	0.230		91.09	0.579	157.25	0.230
2014	106.48	0.746	142.65	0.277		95.26	0.717	132.88	0.259
2015	100.59	0.661	152.16	0.370		100.40	0.657	152.72	0.370
2016	122.06	0.802	152.18	0.467		108.78	0.744	146.21	0.409
2017	164.71	0.744	221.32	0.368		111.57	0.671	166.22	0.335
2018	167.13	0.827	202.15	0.344		123.87	0.796	155.52	0.344

Section 4 - Service Area Map





Section 5 - Top 1% of Worst Performing Circuits (WPC), excluding MED



- Tables of Worst Performing Circuits
- Tables of deficient WPC
- Explanation of why it was ranked as a deficient WPC

Table 5-1: Worst SAIDI Circuits based upon 2017-2018 data (Excludes Planned and MED)

		Circuit		Circuit	%	%	Annualized Feeder	Annualized Total Circuit
Circuit	District	Customers	Substation Name	Miles	ОН	UG	Outage Count	SAIDI **
*1215	Eastern	154	CRESTWOOD	23.8	97%	3%	8	3863
*440	Eastern	266	GLENCLIFF	23.2	86%	14%	6	3824
*441	Eastern	106	GLENCLIFF	27.8	90%	10%	4	3550
445	Eastern	961	BOULEVARD	108.2	95%	5%	6	1411
CE1	Metro	141	CENTRAL	1.4	0%	100%	3	1215
*212	Northeast	662	WARNERS	118.4	96%	4%	5	1166
*78	Eastern	269	DESCANSO	14.9	85%	15%	3	1099
*220	Northeast	339	SANTA YSABEL	55.1	95%	5%	2	1033
*448	Eastern	999	CAMERON	87.4	94%	6%	4	1011
79	Eastern	879	DESCANSO	76.7	93%	7%	9	968

^{*} Circuit appeared on previous years worst performance list

^{**} Circuit SAIDI represents all outages: Feeder and Branch

Section 6 - Top 10 Major Unplanned Outages within the Reporting Year



- Outage events including the outage cause for 2018
 - Based upon customer impact
 - High Wind events were a major factor during Santa Ana/Red Flag Warnings in November, especially with Public Safety Power Shutoff program in effect.

	Top 10 Major Unplanned Power Outage Events										
Rank	Outage Date	Cause	Location	Customer Impact	SAIDI	SAIFI					
1	11/11/2018	High Winds / RFW spanning multiple days	CM, EA, NC, NE	35481	43.98	0.024					
2	1/31/2018	Substation - Bushings	CM, EA	29338	2.55	0.020					
3	10/12/2018	Lightning Storm	BC, EA, NC, NE	20002	1.23	0.014					
4	4/20/2018	Substation - Animal Contact	BC	15554	0.75	0.011					
5	5/26/2018	Substation - Jumper	CM	12601	0.72	0.009					
6	12/6/2018	Faulted Recloser	CM, EA, NE, OC	12070	1.27	0.008					
7	1/25/2018	Substation - Animal Contact	NC	11683	0.48	0.008					
8	11/30/2018	Substation - Equipment	CM	8506	0.53	0.006					
9	11/7/2018	Gas hazard - Circuits de-energized for safety	NC	6992	0.40	0.005					
10	1/9/2018	Rain Storm	All Districts	6286	0.64	0.004					

Section 7 - Summary List of 2018 MED



San Diego Gas & Electric – Summary list of 11/12/18 MED

			Number of			Customer	rs Interrupt	ed - Hours	Into the Ev	ent Day *		
			Customers Out									
Date of Outage	Description of Outage	Location	of Service	0	2	4	6	8	10	12	14	16
November 12	Winds / RFW	BC, CM	23,883	0	0	2	1813	7179	10950	15210	18443	11788
		EA, NC, NE			Cust	omers Inte	errupted - H	lours Into t	the Event [ay (contin	ued)	
				18	20	22	24	26	28	30	32	34
				10887	9890	11940	11940	11746	11746	11746	11746	11746
					Cust	omers Inte	errupted - H	lours Into t	the Event [ay (contin	ued)	
				36	38	40	42	44	46	48	50	52
				11212	11212	10942	9529	9121	9121	9121	9121	9121
					Cust	tomers Inte	errupted - H	lours Into t	the Event [ay (contin	ued)	
				54	56	58	60	62	64	66	68	70
				9121	9121	9121	9121	8577	6462	4886	4569	3957
					Cust	omers Inte	errupted - H	lours Into 1	the Event D	ay (contin	ued)	
				72	74	76	78	80	82	84	86	88
				3319	3319	3319	3319	3319	3273	2855	1705	1404
				Customers Interrupted - Hours Into the Event Day (continued)								
				90	92	94	96	98	100			
				712	3	3	3	3	0			

Customers reflected in the time increments represent all customers experiencing sustained outages at that point in time. The event day begins at midnight. For 2018, Major Event Days included the Santa Ana/RFW episode in November, due in part to the Public Safety Power Shutoff program.

Section 8 - Historical 10 Largest Unplanned Outage Events for the past 10 Years



Tables capture the ten largest unplanned outage events for each of the years from 2018 through 2009. The December outages were a function of the Santa Ana/RFW episode, due to high winds and Public Safety Power Shutoff program.

2018

	Historical 10 Largest Unplanned Outage Events									
Rank	Date	SAIDI	SAIFI	Description						
1	11/11/2018	43.98	0.024	High Winds / RFW spanning multiple days						
2	1/28/2018	3.87	0.003	High Wind Event						
3	1/31/2018	2.55	0.020	Substation - Bushings						
4	7/6/2018	1.66	0.002	Brush Fire						
5	11/12/2018	1.37	0.001	Substation - Undetermined Cause						
6	12/6/2018	1.27	0.008	Faulted Recloser						
7	10/12/2018	1.23	0.014	Lightning Storm						
8	7/7/2018	1.12	0.003	Vehicle Contact						
9	2/25/2018	1.06	0.004	Tee Failure						
10	9/13/2018	0.96	0.004	Switch Failure						

Section 9 - Website - Outage Inquiries





sdge.com/system-reliability

Social Media



Connect with us on our social media channels



Twitter.com/sdge



Facebook.com/SanDiegoGasandElectric



Pinterest.com/sdge




YouTube.com/SDGEWebmaster



LinkedIn.com/company/san-diego-gas-&-electric

Customer Engagement Channels







Outage Tools for Customers



Outage Map





Mobile App



Outage Video



Summary



- Classification of Assets
- Reliability
 - SAIDI
 - SAIFI
 - CAIDI
 - MAIFI
 - MED
- SDG&E Reliability Efforts
 - FiRM
 - Vegetation Management
 - Data Gathering/Circuit Analysis
 - Business Services Project Coordination
 - Meteorology
 - Others
- Comparison of 3 Largest IOUs in California

Summary Cont.



- SDG&E 2018 Annual Report available on CPUC website
- Social Media
- Customer Service
- Customer Engagement Channels
- Outage Tools for Customers