

**SAN DIEGO GAS & ELECTRIC COMPANY
SOUTHERN CALIFORNIA GAS COMPANY**

**CERTIFICATE OF PUBLIC CONVENIENCE & NECESSITY FOR THE
PIPELINE SAFETY & RELIABILITY PROJECT - CPCN**

(A.15-09-013)

(DATA REQUEST TURN-01 SUPPLEMENTAL)

Date Requested: November 11, 2015

Date Responded: December 7, 2015

QUESTION 1:

Please provide the total number of interruptions to SDG&E's customers due to a lack of natural gas in the past five years. Please provide any reports, either internal or submitted to the CPUC, concerning each interruption event.

RESPONSE 1:

As clarified in TURN's e-mails dated November 11, 2015 and November 24, 2015, SDG&E and SoCalGas interpret "interruptions due to a lack of natural gas" to mean curtailment of gas service to electric generation (EG) customers.

Provided below is a list of outages responsive to this supplemental question:

Curtailment Event Log				
Advice Letter	Date of Event	Type of Event	Utility	Local Service Areas
4207	Feb 3 - 7, 2011	Localized	SCG/SDGE	Southern System - East of Moreno; Southern System - South of Moreno
N/A	Oct 1-3, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Oct 8-9, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Oct 15-16, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Oct 22-23, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Oct 29-30, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Nov 5-6, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Nov 12-13, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
N/A	Nov 19-20, 2011	Planned Maintenance	SDGE	Southern System - South of Moreno
4576	Dec 6 - 11, 2013	Standby Procurement Services	SCG/SDGE	Systemwide
4603	Feb 6 - 10, 2014	Standby Procurement Services	SCG/SDGE	Systemwide
4604	Feb 6 - 10, 2014	Emergency Localized	SCG/SDGE	Southern System - East of Moreno; Southern System - South of Moreno
4604	Feb 6 -10, 2014	Emergency	SCG/SDGE	Systemwide

**SAN DIEGO GAS & ELECTRIC COMPANY
SOUTHERN CALIFORNIA GAS COMPANY**
**CERTIFICATE OF PUBLIC CONVENIENCE & NECESSITY FOR THE
PIPELINE SAFETY & RELIABILITY PROJECT - CPCN**
(A.15-09-013)
(DATA REQUEST TURN-01 SUPPLEMENTAL)
Date Requested: November 11, 2015
Date Responded: December 7, 2015

QUESTION 2:

Please provide a projection of future interruption to SDG&E customers due to a lack of natural gas in the next 20 (2010-2030) years if the new 36" pipeline is not built and if the 36" pipeline is built.

RESPONSE 2:

No such forecasts are available.