

2025

ELECTRIC DISTRIBUTION DESIGN MANUAL

FIELD MAINTENANCE ONLY

Historical Record: 8/22/2025
External Version



| | |
|-----------------------------|------|
| GENERAL INFORMATION | 5000 |
| OVERHEAD LAYOUT SYSTEMS | 5100 |
| UNDERGROUND LAYOUT SYSTEMS | 5200 |
| DEMAND ESTIMATING | 5300 |
| VOLTAGE DROP | 5400 |
| CONDUCTOR AMPACITIES | 5500 |
| TRANSFORMERS | 5600 |
| PADS & SUBSTRUCTURES | 5700 |
| CAPACITORS | 5800 |
| WIRE & SUPPORTS | 5900 |
| SUBSTATION LOAD FORECASTING | 6000 |
| SECTIONALIZING & PROTECTION | 6100 |
| SYSTEM ENGINEERING | 6200 |
| SUBSTATION ENGINEERING | 6300 |
| INTRODUCTION | |
| DISCLAIMER & CONTACTS | |
| SUMMARY OF CHANGES | |

ATTENTION:

- The contents held within this book are for field maintenance only. Every effort should be made, when possible, to upgrade to current standards.

IF YOU HAVE ANY QUESTIONS REGARDING THE CONTENT OF THESE MANUALS, PLEASE EMAIL
CONSTRUCTIONSTANDARDSADMINISTRATORS@SEMPRAUTILITIES.COM OR CONTACT:

5000
GENERAL
INFORMATION

5000
GENERAL
INFORMATION

5000 - No FMO standards for this section.

5100
OVERHEAD LAYOUT
SYSTEMS

5100
OVERHEAD LAYOUT
SYSTEMS

5100 - No FMO standards for this section.

**5200
UNDERGROUND
LAYOUT SYSTEMS**

5200
UNDERGROUND
LAYOUT SYSTEMS

SUBJECT

5223

SINGLE FAMILY RESIDENTIAL SECONDARY SYSTEMS

| © 1998 - 2025 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law. | | | | | | | | | | | | | | | | |
|--|----------------|--|---------------------------|-----|-----|------------|--------------------|--------|----|----|----------|-----|------|---------------------|--|---------------|
| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE | | | |
| C | | | | | | | F | | | | | | | | | |
| B | | | | | | | E | | | | | | | | | |
| A | ORIGINAL ISSUE | JKI | KNM | FRC | KRG | 02/13/2025 | D | | | | | | | | | |
| SHEET 1 OF 1 | | | Indicates Latest Revision | | | | Completely Revised | | | X | New Page | | | Information Removed | | FMO DM5201 |
| | | SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FIELD MAINTENANCE ONLY | | | | | | | | | | | | | | |
| | | TABLE OF CONTENTS UNDERGROUND LAYOUT SYSTEMS | | | | | | | | | | | | | | |

DM5223 FIELD MAINTENANCE ONLY

ALL VERSIONS LISTED IN FMO ARE SUPERSEDED BY THEIR CURRENT VERSION FOUND INSIDE THE ELECTRIC DISTRIBUTION DESIGN MANUAL.

REVISION HISTORY:

02/21/2025: DM5223 MOVED TO FMO

© 1998 - 2025 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law.

| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE | | | |
|-----------------|-------------------|--|---------------------------|-----|-----|------------|--------------------|--------|----|----|----------|-----|------|---------------------|--|---------------|
| C | | | | | | | F | | | | | | | | | |
| B | | | | | | | E | | | | | | | | | |
| A | 6114 MOVED TO FMO | JIK | KNM | FRC | KRG | 02/13/2025 | D | | | | | | | | | |
| SHEET 1 OF 1 | | | Indicates Latest Revision | | | | Completely Revised | | | X | New Page | | | Information Removed | | FMO DM5223 |
| | | SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FIELD MAINTENANCE ONLY | | | | | | | | | | | | | | |
| | | SINGLE FAMILY RESIDENTIAL SECONDARY SYSTEMS | | | | | | | | | | | | | | |

This design standard provides the residential secondary and service system optimum array tables used in conjunction with the General Design Criteria provided in Design Manual 5222. These tables represent an economic analysis of secondary and service system design alternatives, on a cost per lot basis, for approximately 9600 different array possibilities.

The optimum array tables shall be used for residential single-family subdivision design to insure the lowest cost system is installed.

NONE

A. The optimum array tables provide the optimum array configuration, transformer size and secondary/service cable selections based on KW demand, secondary distance, and service distance. The instructions for properly applying the optimum array tables are as follows:

- Determine the KW demand per lot for the subdivision from the Residential Demand Estimating Criteria, Design Manual 5322.


- The secondary footage and structure (Transformer Pad or Handhole) placement is dictated by the lot front footage, street width, and meter location. Typically, the structures will be placed at the load center to serve as many meters as possible from one location. This requires the secondary footage to span from one to four lots or the street width. Therefore, the secondary footage is determined by:

- a. Measuring the distance across the number of lots being spanned or the distance across the street
- b. Adding footage to the overall distance for cable tools (Design Manual 5922). The typical secondary footage for a subdivision should be determined by measuring several lot combinations and using the most common footage(s) as a benchmark for optimum array selections.

- The service distance for a single-sided array service or double-sided array short service is equal to the service panel setback. The double-sided array long service is equal to the service panel setback plus the distance from the originating structure across the street to the property line. The service panel setback is either an estimated or measured distance from behind the sidewalk at the property line to the service panel location. Additional footage shall be added to this distance from the service cable tails (Design Manual 5922).

- Select the subdivision single-sided and/or double-sided optimum array configuration from the table with the appropriate KW demand, secondary and service lengths. The optimum array selection for the subdivision may be used for each individual array whose secondary and service footage does not differ from the typical by more than ten feet. Otherwise, an individual array selection must be made.

© 1998-2020 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law.

| REV | CHANGE | BY | DSGN | APPV | DATE | REV | CHANGE | BY | DSGN | APPV | DATE |
|-----------------|----------------|---|------|--------------------|------------|----------|--------|---------------------|------|-----------------|------|
| C | | | | | | F | | | | | |
| B | FORMATTING | JK | - | - | 02/21/2020 | E | | | | | |
| A | ORIGINAL ISSUE | - | CVN | RDG | 01/01/1987 | D | | | | | |
| SHEET 1 OF 7 | |  Indicates Latest Revision | | Completely Revised | | New Page | | Information Removed | | FMO DM5223.1 | |
| | | SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FIELD MAINTENANCE ONLY | | | | | | | | | |
| | | SINGLE FAMILY RESIDENTIAL SECONDARY SYSTEMS | | | | | | | | | |



Sq. Ft.: 0-299

Sq. Ft.: 1300-1999

H1-H4 SHORT=1/0-1/0

Sq. Ft.: 2000-2999

SINGLE-SIDED

| 6.5kW EH & EWH | | | | 6kW A/C & EWH | | | |
|----------------|---------|-------------|--------|---------------|---------|---------|--------|
| Sec Ft | Serv Ft | S1-S2 | # Cust | Sec Ft | Serv Ft | S1-S2 | # Cust |
| 50kVA | | | | 50kVA | | | |
| 80 | 30 | 3/0-3/0-1/0 | 14 | 80-70 | 20-50 | 1/0-1/0 | 10 |
| 80 | 30-50 | 1/0-1/0 | 10 | 80 | 20-50 | 1/0-1/0 | 10(a) |
| 80 | 20-50 | 1/0-1/0 | 10 | 90 | 20 | 3/0-1/0 | 10 |
| 80 | 20 | 3/0-1/0 | 10 | 90 | 30-50 | 3/0-1/0 | 10(a) |
| 25kVA | | | | 25kVA | | | |
| 80 | 30-50 | #2 | 6 | 100 | 20 | 3/0-3/0 | 10 |
| 90-110 | 20-50 | #2 | 6 | 100 | 30-50 | 3/0-3/0 | 10(a) |
| 120-150 | 20-50 | 1/0 | 6 | 110 | 20-50 | 3/0-3/0 | 10(a) |
| | | | | 120 | 20-40 | 3/0-3/0 | 8(a) |
| | | | | 120 | 50 | 3/0-3/0 | 8(a) |
| | | | | 25kVA | | | |
| | | | | 130 | 20-40 | 1/0 | 6 |
| | | | | 130 | 50 | 1/0 | 6 |
| | | | | 140-150 | 20-40 | 1/0 | 6 |
| | | | | 140-150 | 50 | 1/0 | 8(r) |

SINGLE-SIDED

| 7.5kW EH & EWH | | | | 7kW A/C & EWH | | | |
|----------------|---------|---------|--------|---------------|---------|---------|--------|
| Sec Ft | Serv Ft | S1-S2 | # Cust | Sec Ft | Serv Ft | S1-S2 | # Cust |
| 50kVA | | | | 75kVA | | | |
| 80 | 20-30 | 1/0-1/0 | 10 | 80 | 20-40 | 3/0-1/0 | 10 |
| 80 | 40-50 | 1/0-1/0 | 10(a) | 80 | 20-50 | 3/0-1/0 | 10(a) |
| 80 | 20-50 | 3/0-1/0 | 10 | 70 | 20-50 | 3/0-3/0 | 10 |
| 80-90 | 20-50 | 3/0-3/0 | 10 | 80 | 20-40 | 3/0-3/0 | 10 |
| 100 | 20 | 3/0-3/0 | 10 | 80 | 50 | 3/0-3/0 | 10(a) |
| 100 | 30-50 | 3/0-3/0 | 10(a) | 80 | 20-30 | 3/0-3/0 | 10 |
| 110 | 20-40 | 3/0-3/0 | 10(a) | 80 | 40 | 3/0-3/0 | 10(a) |
| 110 | 50 | 3/0-3/0 | 10(a) | 90 | 50 | 3/0-3/0 | 10(a) |
| 120-150 | 20-50 | 1/0 | 8 | 100 | 20 | 3/0-3/0 | 10 |
| | | | | 100 | 30-40 | 3/0-3/0 | 10(a) |
| | | | | 100 | 50 | 3/0-3/0 | 10(a) |
| | | | | 50kVA | | | |
| | | | | 110 | 20-40 | 1/0 | 6 |
| | | | | 110 | 50 | 3/0 | 6 |
| | | | | 120 | 20-30 | 1/0 | 6 |
| | | | | 120 | 40 | 1/0 | 6 |
| | | | | 120 | 50 | 3/0 | 8(r) |
| | | | | 130 | 20-30 | 1/0 | 6 |
| | | | | 130 | 40 | 1/0 | 6 |
| | | | | 130 | 50 | 3/0 | 8(r) |
| | | | | 140 | 20-30 | 1/0 | 6 |
| | | | | 140 | 40-50 | 3/0 | 6 |
| | | | | 150 | 20-40 | 3/0 | 6 |
| | | | | 150 | 50 | 3/0 | 8(r) |

SINGLE-SIDED

| 8kW EH & EWH | | | | 8kW A/C & EWH | | | |
|--------------|---------|---------|---------|---------------|---------|---------|--------|
| Sec Ft | Serv Ft | S1-S2 | # Cust | Sec Ft | Serv Ft | S1-S2 | # Cust |
| 50kVA | | | | 75kVA | | | |
| 80 | 20 | 1/0-1/0 | 10 | 80 | 20-40 | 3/0-1/0 | 10 |
| 80 | 30-50 | 1/0-1/0 | 10(a) | 80 | 50 | 3/0-1/0 | 10(a) |
| 70 | 20-50 | 3/0-1/0 | 10 | 70 | 20-30 | 3/0-1/0 | 10 |
| 80 | 20-50 | 3/0-3/0 | 10 | 70 | 40-50 | 3/0-1/0 | 10(a) |
| 80 | 20 | 3/0-3/0 | 10 | 80 | 20-40 | 3/0-3/0 | 10 |
| 80 | 30-50 | 3/0-3/0 | 10(a) | 80 | 50 | 3/0-3/0 | 10(a) |
| 100 | 20 | 3/0-3/0 | 10 | 90 | 20-30 | 3/0-3/0 | 10 |
| 100 | 30 | 3/0-3/0 | 10 | 80 | 40 | 3/0-3/0 | 10(a) |
| 100 | 40-50 | 3/0-3/0 | 8(a)(b) | 90 | 50 | 3/0-3/0 | 10(a) |
| 110-150 | 20-50 | 1/0 | 8 | 100 | 20 | 3/0-3/0 | 10 |
| | | | | 100 | 30 | 3/0-3/0 | 10(a) |
| | | | | 100 | 50 | 3/0-3/0 | 10(a) |
| | | | | 50kVA | | | |
| | | | | 100 | 40 | 1/0 | 6 |
| | | | | 110 | 20-30 | 1/0 | 6 |
| | | | | 110 | 40-50 | 1/0 | 6(r) |
| | | | | 120 | 20-30 | 1/0 | 6 |
| | | | | 120 | 40-50 | 1/0 | 6(r) |
| | | | | 130 | 20 | 1/0 | 6 |
| | | | | 130 | 30-40 | 1/0 | 6(r) |
| | | | | 140 | 20 | 3/0 | 6 |
| | | | | 140 | 20 | 1/0 | 6 |
| | | | | 140 | 40-50 | 3/0 | 6(r) |
| | | | | 150 | 20 | 3/0 | 6 |
| | | | | 150 | 30-40 | 3/0 | 8(r) |
| | | | | 150 | 50 | 3/0 | 8(r) |

o)H2=1/0, b)H3=1/0, c)H1=1/0, d)H4=1/0, e)H2-H5=1/0-1/0, f)H1-H4=1/0-1/0, g)H2-H4=1/0-1/0
h)H3-H5=1/0-1/0, i)H3-H5=1/0-1/0, j)H2=3/0, k)H3-H5=3/0-1/0, m)H2-H4=1/0-3/0, n)H1-H4=3/0-3/0
o)H2-H5=3/0-3/0, p)H2-H4=3/0-3/0, q)H1-H2-H4=1/0-1/0-1/0, r)H1=3/0
s)S4=#2, t)S4=1/0, u)S4-S5=1/0-#2, v)S4-S5=1/0-1/0, w)S2-S4=3/0-1/0, x)S4=3/0

DOUBLE-SIDED

| 6.5kW EH & EWH | | | | 6kW A/C & EWH | | | |
|----------------|---------|---------|--------|---------------|---------|---------|----------|
| Sec Ft | Serv Ft | S1-S2 | # Cust | Sec Ft | Serv Ft | S1-S2 | # Cust |
| 75kVA | | | | 75kVA | | | |
| 80 | 80-90 | 3/0-3/0 | 20 | 80 | 80-100 | 3/0-3/0 | 16(a)(b) |
| 80 | 100-150 | 3/0-3/0 | 20(a) | 80 | 110-150 | 3/0-3/0 | 16(a)(b) |
| 70 | 80-100 | 3/0-3/0 | 20(a) | 70 | 80-100 | 1/0 | 12 |
| 50kVA | | | | 50kVA | | | |
| 70 | 110-150 | 1/0 | 12 | 70 | 110-150 | 350-3/0 | 16(a)(b) |
| 80 | 80-110 | 1/0 | 12 | 80 | 80-90 | 1/0 | 12 |
| 80 | 120-150 | 1/0 | 12(r) | 80 | 100-130 | 350-3/0 | 16(a)(b) |
| 80 | 80-100 | 1/0 | 12 | 80 | 140-150 | 3/0 | 12(r) |
| 90 | 110-150 | 1/0 | 12(r) | 90 | 80-90 | 1/0 | 12 |
| 100 | 80 | 1/0 | 12 | 90 | 100-150 | 1/0 | 12(r) |
| 100 | 90-150 | 1/0 | 12(r) | 100 | 80 | 1/0 | 12 |
| 110 | 80-110 | 1/0 | 12 | 100 | 90-130 | 1/0 | 12(r) |
| 110 | 120-140 | 3/0 | 12(r) | 100 | 140-150 | 3/0 | 12(r) |
| 120 | 80-110 | 3/0 | 12 | 110 | 80-130 | 1/0 | 12(r) |
| 120 | 120-150 | 3/0 | 12(r) | 110 | 140-150 | 3/0 | 12(r) |
| 130 | 80-110 | 3/0 | 12 | 120 | 80-110 | 1/0 | 12(r) |
| 140 | 80-100 | 3/0 | 12 | 120 | 120-140 | 3/0 | 12(r) |
| 140 | 100-150 | 3/0 | 12(r) | 120 | 150 | 3/0 | 12(n) |
| 150 | 80-90 | 3/0 | 12 | 130 | 80-90 | 3/0 | 12 |
| | | | | 130 | 100-150 | 3/0 | 12(r) |
| | | | | 140 | 80-100 | 3/0 | 12 |
| | | | | 140 | 100-130 | 3/0 | 12(r) |
| | | | | 140 | 140-150 | 3/0 | 12 |
| | | | | 150 | 80-90 | 3/0 | 12(r) |
| | | | | 150 | 100-120 | 3/0 | 12(r) |
| | | | | 150 | 130-150 | 3/0 | 12(n) |

DOUBLE-SIDED

| 7.5kW A/C & EWH | | | | 7kW A/C & EWH | | | |
|-----------------|---------|---------|--------|---------------|---------|---------|--------|
| Sec Ft | Serv Ft | S1-S2 | # Cust | Sec Ft | Serv Ft | S1-S2 | # Cust |
| 75kVA | | | | 100kVA | | | |
| 80 | 150 | 350-3/0 | 16(a) | 80 | 150 | 350-3/0 | 16(a) |
| 70 | 150 | 350-3/0 | 16(a) | 70 | 150 | 350-3/0 | 16(a) |
| 80 | 150 | 350-350 | 16(a) | 80 | 150 | 350-350 | 16(a) |
| 75kVA | | | | 75kVA | | | |
| 80 | 80-120 | 1/0 | 12(r) | 80 | 80-120 | 1/0 | 12(r) |
| 60 | 130-140 | 3/0 | 12(r) | 60 | 130-140 | 3/0 | 12(r) |
| 70 | 80 | 3/0 | 12 | 70 | 80 | 3/0 | 12 |
| 70 | 90-140 | 3/0 | 12(r) | 70 | 90-140 | 3/0 | 12(r) |
| 80 | 90 | 3/0 | 12 | 80 | 90 | 3/0 | 12 |
| 80 | 90-130 | 3/0 | 12(r) | 80 | 90-130 | 3/0 | 12(r) |
| 80 | 140 | 3/0 | 12(r) | 80 | 140 | 3/0 | 12(r) |
| 90 | 80 | 3/0 | 12 | 90 | 80 | 3/0 | 12 |
| 90 | 90-120 | 3/0 | 12(r) | 90 | 90-120 | 3/0 | 12(r) |
| 90 | 130-150 | 3/0 | 12(r) | 90 | 130-150 | 3/0 | 12(r) |
| 100 | 80-120 | 3/0 | 12(r) | 100 | 80-120 | 3/0 | 12(r) |
| 100 | 130-150 | 3/0 | 12(r) | 100 | 130-150 | 3/0 | 12(r) |
| 100 | 80-110 | 3/0 | 12(r) | 100 | 80-110 | 3/0 | 12(r) |
| 110 | 120-150 | 3/0 | 12(r) | 110 | 120-150 | 3/0 | 12(r) |
| 120 | 80-100 | 3/0 | 12(r) | 120 | 80-100 | 3/0 | 12(r) |
| 120 | 110-150 | 3/0 | 12(r) | 120 | 110-150 | 3/0 | 12(r) |
| 130 | 80-110 | 3/0 | 12(r) | 130 | 80-110 | 3/0 | 12(r) |
| 130 | 110-150 | 3/0 | 12(r) | 130 | 110-150 | 3/0 | 12(r) |
| 140 | 80-90 | 3/0 | 12(r) | 140 | 80-90 | 3/0 | 12(r) |
| 140 | 100-140 | 3/0 | 12(r) | 140 | 100-140 | 3/0 | 12(r) |
| 140 | 150 | 350 | 12(n) | 140 | 150 | 350 | 12(n) |
| 150 | 80-90 | 3/0 | 12(r) | 150 | 80-90 | 3/0 | 12(r) |
| 150 | 100-140 | 3/0 | 12(n) | 150 | 100-140 | 3/0 | 12(n) |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

**5300
DEMAND
ESTIMATING**

**5300
DEMAND
ESTIMATING**

5300 - No FMO standards for this section.

5400

VOLTAGE DROP

5400

VOLTAGE DROP

5400 - No FMO standards for this section.

**5500
CONDUCTOR
AMPACITIES**

5500
CONDUCTOR
AMPACITIES

5500 - No FMO standards for this section.

5600

TRANSFORMERS

5600

TRANSFORMERS

5600 - No FMO standards for this section.

**5700
PADS &
SUBSTRUCTURES**

**5700
PADS &
SUBSTRUCTURES**

5700 - No FMO standards for this section.

5800
CAPACITORS

5800
CAPACITORS

5800 - No FMO standards for this section.

5900

WIRE & SUPPORTS

5900

WIRE & SUPPORTS

5900 - No FMO standards for this section.

6000
SUBSTATION
LOAD FORECASTING

6000
SUBSTATION
LOAD FORECASTING

6000 - No FMO standards for this section.

6100
SECTIONALIZING
& PROTECTION

6100
SECTIONALIZING
& PROTECTION

SUBJECT

6114

UNDERGROUND SERVICE RESTORER

| © 1998 - 2024 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law. | | | | | | | | | | | | | | | | |
|--|-------------------|--|---------------------------|-----|-----|------------|--------------------|--------|----|----|----------|-----|------|---------------------|--|---------------|
| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE | | | |
| C | | | | | | | F | | | | | | | | | |
| B | | | | | | | E | | | | | | | | | |
| A | 6114 MOVED TO FMO | JIK | MAK | FRC | KRG | 09/16/2024 | D | | | | | | | | | |
| SHEET 1 OF 1 | | | Indicates Latest Revision | | | | Completely Revised | | | X | New Page | | | Information Removed | | FMO DM6101 |
| | | SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FIELD MAINTENANCE ONLY | | | | | | | | | | | | | | |
| | | TABLE OF CONTENTS SECTIONALIZING AND PROTECTION | | | | | | | | | | | | | | |

DM6114 FIELD MAINTENANCE ONLY

ALL VERSIONS LISTED IN FMO ARE SUPERSEDED BY THEIR CURRENT VERSION FOUND INSIDE THE ELECTRIC DISTRIBUTION DESIGN MANUAL.

REVISION HISTORY:

09/16/2024: MOVED TO FMO

© 1998 - 2024 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law.

| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE |
|-----|-------------------|-----|-----|-----|-----|------------|-----|--------|----|----|-----|-----|------|
| C | | | | | | | F | | | | | | |
| B | | | | | | | E | | | | | | |
| A | 6114 MOVED TO FMO | JIK | MAK | FRC | KRG | 09/16/2024 | D | | | | | | |

SHEET
1 OF 1

Indicates Latest Revision

Completely Revised

New Page

Information Removed

SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FIELD MAINTENANCE ONLY

UNDERGROUND SERVICE RESTORER

FMO
DM6114

SCOPE

This document provides criteria for the selection and application of 12KV feeder sectionalizing devices on selected high-risk circuits.

PURPOSE

Application of automatic sectionalizing devices for underground circuits (pad-mounted service restorer and PME3 with SCADA) can be beneficial in reducing the number of customers affected by service interruptions. These devices are also helpful in reducing the projected SAIDI by minimizing the impact of a failure of the unfused high molecular polyethylene (HMWPE or PECH in GFMS or unjacketed cross-linked polyethylene (XLPE) cable.

CRITERIA


- A. Circuits chosen for study should meet one or more of the following:
 - 1. A high amount of unfused type HMWPE or XLPE cable as defined by
 - a. Total cable length exceeding one mile or
 - b. Exceeding 20 percent of the total underground cable length
 - 2. Underground outage history exceeding three feeder outages over the last three years regardless of cause.
- B. In addition to the above, the application must be prioritized based on the cost-to-benefit (C/B) ratio analysis in Design Manual section 6145. The projected value (the inverse of the C/B ratio) must be greater than one to justify the additional sectionalizing devices. Alternate methods of project methods of project justification may be allowed by Electric Distribution Planning.

APPLICATION

The circuit under consideration must be examined to ensure that it will meet the switching provisions of Design Manual section 6111 after modification. Service restorers are the preferred device because of the automatic operation and the fact that they can immediately reduce the number of customers affected by an outage. If a service restorer is already in use on a circuit, the PME3 with SCADA should be used where substation SCADA is available or will be available within two years. In cases where the frequency is not as critical, the PME3 with SCADA may be the most economical choice.


- 1. 600A Padmounted Service Restorer
 - a. Consideration must be made regarding the location and length of the unfused cable segments when locating the service restorer. As a general guide, locate the service to maximize the amount of load on the line side of the device and to maximize the circuit length on load side. The service restorer should be located to protect at least one half of the circuit load. If this is not practical, locate to maximize the isolation of the unfused cable sections.
 - b. A line switch is required immediately ahead of the service restorer for maintenance. This may be an overhead gang operated or hookstick switch, a padmount switch, a handhole switch (On-Off), or a manhole switch (group/On-Off). Manhole switches are acceptable for this application but they are not preferred.

FOR FIELD MAINTENANCE ONLY

| | | | | | |
|--------------------------------------|---|---------------------------|--------------------|----------|---------------------|
| |  | Indicates Latest Revision | Completely Revised | New Page | Information Removed |
| REVISION | SDG&E DISTRIBUTION DESIGN MANUAL | | | | |
| DATE 3-1-02 APPD JCE / <i>WJL</i> | UNDERGROUND SERVICE RESTORER APPLICATION CRITERIA | | | | 6114.1 |

APPLICATION (continued)

- c. No load should be connected between the service restorer and the line switch immediately ahead. An exception to this rule would be the placement of a single phase transformer that would only provide secondary service for the actuator device within the service restorer. This single phase transformer may tap the feeder at either the switch, the service restorer or in between. Following is an illustrative one-line diagram for the three optional hookups.



Special Note: DM 6121.3.d.1 requires that a fuse request be submitted and approved prior to installation of un-fused transformer stations.

- d. If the service restorer is located so as to protect a purely underground section it shall be set for one test reclosing 5 seconds after the fault, then lockout. Distribution Planning will determine the number of test reclosings for circuits with overhead spans on the load side of the service restorer.
- e. Distribution Planning must be contacted to obtain settings for all protective devices on the circuit.

2. PME3 with SCADA or SCADA Overhead Switch

The PME3 with SCADA should be applied in cases where: 1) A feeder has an existing service restorer and protection (fuse) coordination is not possible. 2) The less expensive SCADA switch will provide adequate protection for the circuit being studied.

- a. If existing subsurface or padmount switchgear is strategically placed for service restoration contact Electric Distribution Standards about SCADA actuator retro-fit. This option can be more economical than other options.
- b. Install SCADA type switches at the midpoint, one-quarter and three-quarter points on the feeder in that order of preference. These may be the new PME3 SCADA switch, SCADA overhead switch, or an existing underground switch retro-fitted with SCADA.
- c. SCADA operated devices may be installed on feeders from current non-SCADA substations where SCADA is not planned within two years. Substations where SCADA is not planned within two years will limit options to automatic protection devices.
- d. Consideration should be given to converting strong tie switches to SCADA.

FOR FIELD MAINTENANCE ONLY

| | | | | |
|--------|---|--------------------|----------|----------------------------|
| | Indicates Latest Revision | Completely Revised | New Page | Information Removed |
| 6114.2 | SDG&E DISTRIBUTION DESIGN MANUAL | | | REVISION |
| | UNDERGROUND SERVICE RESTORER APPLICATION CRITERIA | | | DATE 1-1-94 APPD MF/ROJ |

**6200
SYSTEM
ENGINEERING**

**6200
SYSTEM
ENGINEERING**

PAGE

SUBJECT

6222

APPLICATION OF GROUNDING BANKS

6242

ECONOMIC EVALUATION OF ALTERNATIVES

© 1998 - 2025 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law.

| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE |
|-----|-------------------|-----|-----|-----|-----|------------|-----|--------|----|----|-----|-----|------|
| C | | | | | | | F | | | | | | |
| B | 6242 MOVED TO FMO | YZZ | FRC | FRC | FRC | 07/18/2025 | E | | | | | | |
| A | 6222 MOVED TO FMO | JIK | FRC | FRC | KRG | 09/16/2024 | D | | | | | | |

SHEET
1 OF 1

X

Indicates Latest Revision

Completely Revised

New Page

Information Removed

SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FOR FIELD MAINTENANCE ONLY

TABLE OF CONTENTS
SYSTEM ENGINEERING

FMO
DM6201.1

ALL VERSIONS LISTED IN FMO ARE SUPERSEDED BY THEIR CURRENT VERSION FOUND INSIDE THE ELECTRIC DISTRIBUTION DESIGN MANUAL.

09/16/2024: MOVED TO FMO

| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE |
|-----|-------------------|-----|-----|-----|-----|------------|-----|--------|----|----|-----|-----|------|
| C | | | | | | | F | | | | | | |
| B | | | | | | | E | | | | | | |
| A | 6114 MOVED TO FMO | JIK | FRC | FRC | KRG | 09/16/2024 | D | | | | | | |

FMO
DM6222

SCOPE

This criteria shall be used for the application of grounding banks. Grounding banks provide a grounded neutral source that is required by load additions which are served by 6.9kV transformers.

DEFINITIONS

A grounding bank installation consists of three-phase transformers connected grounded wye-delta and is used to provide a ground source for the primary neutral wire. The primary voltage rating of the transformers used can be 12 or 6.9kV. The secondary voltage shall be rated 480 volts or higher (see O.H. Standards page 1195).

APPLICATION OF GROUNDING BANKS

A. Why Grounding Banks?





A grounding bank may be installed to serve single-phase load additions using 6.9kV transformers when there are two or fewer grounding banks on a circuit and:

1. Extension of an existing neutral wire, beyond the proper location for a grounding bank, is double the cost of a new grounding bank installation.
2. A neutral connected to an existing grounding bank is available, but additional single-phase load will exceed the recommended kVA limit on the existing grounding bank (see paragraph B.5).

B. Design Considerations

The following lists several design considerations related to the application of grounding banks.


1. The available short-circuit current sensed by a protective device is reduced approximately 100 amps for each grounding bank between the fault location and the substation. To prevent desensitization of the substation ground relays, the number of grounding banks on a circuit is limited to three installations.
2. A grounding bank should be installed at a central location to enable future loads to take advantage of this neutral source. Since there will normally be a maximum of three grounding banks per circuit, each grounding bank should be located to cover one third of the area served by the circuit.

| | | | | | | |
|---|---|---------------------------|---|--------------------|---|----------|
| |  | Indicates Latest Revision |  | Completely Revised |  | New Page |
| REVISION | SDG&E DISTRIBUTION DESIGN MANUAL | | | | | 6222.1 |
| DATE 1-1-87 | APPLICATION OF GROUNDING BANKS | | | | | |
| APPD CVN/  | | | | | | |

3. The recommended location for a grounding bank is on the unfused portion of a circuit, preferably on the feeder because the load on the grounding bank will be served by an energized neutral source except during times when the circuit is interrupted or the grounding bank has failed.
4. Neutrals established by grounding banks should only be used to serve transformers fed from the same circuit.
5. The following are approved grounding bank installations, allowable connected kVA unbalance between phases and maximum connected kVA loading.

| Grounding Bank Installation | Allowable Connected kVA unbalance Between Phases | Maximum Connected kVA Loading ^(a) |
|-----------------------------|--|--|
| 3 – 50 kVA's | 150 kVA | 1500 kVA |
| 3 – 75 kVA's | 225 kVA | 2250 kVA |

- (a) The maximum connected kVA allowed was set at 10 times the unbalance which a grounding bank may tolerate because the load unbalance on the average circuit is 10 percent.
 - b. For more information on overhead grounding banks, refer to O.H. Standards Page 1195.
 6. Single-phase loads served from a grounding bank should be divided equally among the three phases to balance the total load as much as possible.
- If the amount of unbalance cannot be kept within the limits set above, one of the following must be done:
- a. Extend the neutral from the substation and remove the grounding bank. This alternative is recommended if there is significant load growth potential in the area.
 - b. Serve part of the load with 12kV single-phase transformers. Use enough 12kV transformers to reduce the amount of 6.9kV connected kVA below the recommended limit.
 - c. Extend the neutral from another grounding bank, either new or existing, and transfer some 6.9kV load to this neutral. These neutrals are not to be connected to each other.

| | | | |
|--------|---|--------------------|----------------------|
| |  Indicates Latest Revision | Completely Revised | New Page |
| 6222.2 | SDG&E DISTRIBUTION DESIGN MANUAL | | |
| | APPLICATION OF GROUNDING BANKS | | |
| | | | REVISION |
| | | | DATE 1-1-87 |
| | | | APPD CVN/ <i>RDJ</i> |

DM6242 FIELD MAINTENANCE ONLY

ALL VERSIONS LISTED IN FMO ARE SUPERSEDED BY THEIR CURRENT VERSION FOUND INSIDE THE ELECTRIC DISTRIBUTION DESIGN MANUAL.

REVISION HISTORY:

07/18/2025: MOVED TO FMO

© 1998 - 2025 San Diego Gas & Electric Company. All rights reserved. Removal of this copyright notice without permission is not permitted under law.

| REV | CHANGE | DR | BY | DSN | APV | DATE | REV | CHANGE | DR | BY | DSN | APV | DATE |
|-----|----------------|-----|-----|-----|-----|------------|-----|--------|----|----|-----|-----|------|
| C | | | | | | | F | | | | | | |
| B | | | | | | | E | | | | | | |
| A | ORIGINAL ISSUE | YZZ | FRC | FRC | FRC | 07/18/2025 | D | | | | | | |

| | | | | | | | | | |
|-----------------|--|---------------------------|--|--------------------|---|----------|--|---------------------|---------------|
| SHEET 1 OF 1 | | Indicates Latest Revision | | Completely Revised | X | New Page | | Information Removed | FMO DM6242 |
| | SDG&E ELECTRIC DISTRIBUTION DESIGN MANUAL FIELD MAINTENANCE ONLY | | | | | | | | |
| | ECONOMIC EVALUATION OF ALTERNATIVES | | | | | | | | |

SCOPE

This standard provides a method of evaluating various alternatives so that the most economical one is identified. The advancement of an overload project to improve reliability is also discussed. For the latest calculation tools used to determine the present value of electric distribution projects, contact Distribution Planning.

PURPOSE

Present Worth of Annual Revenue Requirements (PWARR) has been selected by the Financial and Economic Analysis section as the appropriate analytical tool for distribution engineering projects. This is because it measures the total impact of a project on SDG&E's customers given the regulated environment of the utility.

DEFINITIONS

LACC (Levelized Annual Capital Cost) – A factor applied to the installed equipment costs to account for the annual levelized depreciation, return on investment, income taxes, property taxes and salvage.

A/P,n – Converts a present value into an annual series of payments over n years. Refer to the Economic Assumptions Manual, Table 2-1, for the current value.

P/A,n – Provides the present value of an annual series of payments made for n years. Refer to the Economic Assumption Manual, Table 2-1, for the current value.

P/F,n – Provides the present value of a future payment made n years from today. Refer to the Economic Assumption Manual, Table 2-1, for the current value.

Inflation Factor – Accounts for the rise in the price of goods and services over n years.

CRITERIA

The capital portion of Equation 1 below converts the equipment installed cost (Cost) into an annual series using the LACC Factor to account for taxes and return on investment. Then it sums all these payments into a present value at the time of construction using the P/A factor. In contrast, the O&M portion accounts for those non-capitalized expenditures which are included at the time of installation (O&M) and so the LACC and P/A factors are not applied.

$$PWARR = [(Inflation\ Factor)(P/F,n)][(Cost)(LACC)(P/A,n)+(O\&M)] \quad \text{Equation 1}$$

$$Inflation\ Factor = (1+i)^n \quad \text{Equation 2}$$

where: i = rate of inflation

| | | | | |
|----------|-------------------|---|---|-----------------------------------|
| | | <input checked="" type="checkbox"/> Indicates Latest Revision | <input type="checkbox"/> Completely Revised | <input type="checkbox"/> New Page |
| REVISION | | SDG&E DISTRIBUTION DESIGN MANUAL | | |
| DATE | 3-1-02 | PWARR ANALYSIS | | |
| APPD | JCE <i>1/6/02</i> | | | |
| | | 6242.1 | | |

APPLICATION

PWARR analysis is used to compare alternative construction projects economically. Normally there are benefits associated with each project which have not been assigned a dollar amount and, therefore have not been considered. When the PWARR of one alternative is within 5 percent of another alternative it is appropriate to consider unassigned benefits (i.e. improvements in customer service, sensitivity to changes in input variables, lowest installed cost, etc.) in the decision.

A typical application of the PWARR analysis is shown in Example 1. It considers delaying the construction of a new circuit for two years by increasing tie capacity, thus allowing a load transfer to occur. The alternative is to construct the new circuit next year. Although the lives of the two alternatives are not the same (one ends in 28 years, the other 30), the Finance and Economic Analysis section feels Equation 1 provides a good approximation provided the difference in lives does not exceed 5 years.

Example 1

One feeder in a 4-EB5" duct is rated at 475 amps but has a projected load of 500 amps next year. To eliminate the projected overload consider shedding 100 amps to an adjacent circuit by constructing a tie next year for \$75k. This will delay having to construct a new circuit, at a cost of \$450k for an additional 2 years. The alternative is to construct the new circuit next year. Which alternative is the least costly considering all costs were provided in next year's dollars?

The following factors were obtained from the economic Assumptions Manual:

$$\begin{aligned} \text{LACC} &= 0.167, \text{ FERC account E367 (book life} = 28 \text{ yrs)} \\ \text{P/A, } 28 &= 8.2217 \\ \text{P/F, } 2 &= 0.8029 \\ \text{A/P, } 2 &= 0.5886 \\ i &= 5\% \end{aligned}$$

ALTERNATIVE 1: Construct a tie next year and defer the new circuit 2 years.

$$\text{Inflation Factor} = (1.05)^2 = 1.1025$$

$$\text{Construct tie PWARR} = (75k)(0.167)(8.2217) = \$102,976$$


$$\begin{aligned} \text{Construct circuit 2 yrs later PWARR} &= (1.1025)(.8029)(450k)(0.167)(8.2217) \\ &= \$546,929 \end{aligned}$$

$$\text{Total Cost } \$649,905$$

ALTERNATIVE 2:

$$\text{Construct circuit next year PWARR} = (450k)(0.167)(8.2217) = \$617,861$$

Conclusion Alternative 2 is approximately 5% less expensive and it should be selected unless there are sufficient unassigned benefits to favor alternative 1.

| | | | |
|--------|---|--------------------|-----------------------|
| |  Indicates Latest Revision | Completely Revised | New Page |
| 6242.2 | SDG&E DISTRIBUTION DESIGN MANUAL | | REVISION |
| | PWARR ANALYSIS | | DATE 1-1-89 |
| | | | APPD CVN / <i>LDJ</i> |

Example 2

Consider advancing the construction of a new circuit 2 years to achieve an annual reliability benefit of \$100,000. The circuit cost is the same as in Example 1. Is this cost effective?

$$\text{Construct line next year} - (450k)(0.167)(8.2217) = \$617,861$$

$$\text{Construct line 2 yrs later} - (1.1025)(0.8029)(450k)(0.167)(8.2217) = \$546,929$$

$$\text{PWARR of advancement} = 617,861 - 546,929 = \$70,932$$

$$\text{C/B ratio} = (70,929)(A/P_2)/100,000 = 0.4175$$

Conclusion: It is cost effective to move the project ahead 2 years.

Example 3

Consider the effect of adding O&M expenditures to the construction in Example 1. O&M associated with constructing the new line is \$75k, \$15k for constructing the tie.

ALTERNATIVE 1:

$$\text{Construct tie line next year} \quad \text{PWARR} = \$102,976 + \$15,000 = \$117,976$$



$$\text{Construct ckt 2 yrs later} \quad \text{PWARR} = \$546,929 = (75k)(1.1025)(.0829) = \$613,319$$

$$\text{Total cost} = \$731,295$$

ALTERNATIVE 2:

$$\text{Construct new circuit next year} \quad \text{PWARR} = \$617,861 + \$75,000 = \$692,861$$

Conclusion: Alternative 2 is still approximately 5% less expensive and should be selected unless there are sufficient unassigned benefits to favor alternative 1.

| | | | | | | |
|--|---|---------------------------|--|--------------------|--|----------|
| |  | Indicates Latest Revision | | Completely Revised | | New Page |
| REVISION | SDG&E DISTRIBUTION DESIGN MANUAL | | | | | 6242.3 |
| DATE 1-1-89 | PWARR ANALYSIS | | | | | |
| APPD CVN  | | | | | | |

6300

**SUBSTATION
ENGINEERING**

6300

**SUBSTATION
ENGINEERING**

6300 - No FMO standards for this section.

